



Langdon Park RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005790	4/1/2021	4/1/2022	1	Cooler	In hallway adjacent to reception	WF-04012021-005790	4/27/2021	FT-FY21-042021-005790-A	<1	FT-FY21-042021-005790-B	<1
WS- 005791	4/1/2021	4/1/2022	1	Cooler	In hallway adjacent to room 206	WF-04012021-005791	4/27/2021	FT-FY21-042021-005791-A	<1	FT-FY21-042021-005791-B	<1
WS- 005793	4/1/2021	4/1/2022	Basement	Cooler	In hallway adjacent to gym 115	WF-04012021-005793	4/27/2021	FT-FY21-042021-005793-A	<1	FT-FY21-042021-005793-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005792	1/27/2021	1/27/2022	1	Food Prep Sink	In kitchen 212	WF-01272021-005792	4/27/2021	FT-FY21-042021-005792-A	<1	FT-FY21-042021-005792-B	<1